

**EU type examination certificate**  
**EU-Baumusterprüfbescheinigung**

**CE-0085CL0214**  
 Product Identification No.  
 Produkt-Identnummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
<b>Distributor</b> <i>Vertreiber</i>	BAXI S.p.A. Via Trozzetti, 20, I-36061 Bassano del Grappa (VI)
<b>Product Category</b> <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
<b>Product Description</b> <i>Produktbezeichnung</i>	Wall hanging condensing combi water heater with full automatic burner control, gas/combustion-air ratio control and secondary heat exchanger
<b>Model</b> <i>Modell</i>	BOYLER CONDENS...; PULSAR CONDENS...
<b>Countries of Destination</b> <i>Bestimmungsländer</i>	AL, AT, BE, BG, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IT, LT, LU, LV, MK, NL, NO, PL, PT, RO, SE, SI, SK, TR
<b>Test Reports</b> <i>Prüfberichte</i>	supplement test: 18/150/3204/033 from 26.04.2018 (EBI)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.09.2017)
<b>Date of Expiry / File No.</b> <i>Ablaufdatum / AZ</i>	28.03.2028 / 20-0330-GEA

70029-04-A0E

05.03.2021 Rie F-1/2  
 Date, Issued by, Sheet, Head of Certification Body  
 Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle




**DAkkS**  
 Deutsche  
 Akkreditierungsstelle  
 D-ZE-16028-01-01

DVGW CERT GmbH  
 Zertifizierungsstelle  
 Josef-Wirmer-Str. 1-3  
 53123 Bonn  
 Tel. +49 228 91 88 - 888  
 Fax +49 228 91 88 - 993  
 www.dvgw-cert.com  
 info@dvgw-cert.com

**Elektrical Data** 230 V AC, 50 Hz, IPX5D  
*Elektrische Daten*

<b>Appliance Categories</b> <i>Gerätekategorien</i>	<b>Supply Pressures</b> <i>Versorgungsdrücke</i>	<b>Countries of Destination</b> <i>Bestimmungsländer</i>	<b>Remarks</b> <i>Bemerkungen</i>
I2E(S)	20/25 mbar	BE	
I2H	20 mbar	DK	
I2N	20/25 mbar	BE	
I3P	37 mbar	BE	
II2E3P	20, 37 mbar	LU	
II2ELL3P	20, 50 mbar	DE	
II2ELw3P	20, 37 mbar	PL	
II2Esi3P	20/25, 37 mbar	FR	
II2H3P	20, 30 mbar	AT, EE, FI, LT, LV, NO, RO, SE, SI	
II2H3P	20, 37 mbar	CZ, ES, GB, GR, HR, IE, IT, PT, SK, TR	
II2H3P	20, 50 mbar	AT	
II2HM3P	20, 37 mbar	IT	
II2HS3P	25, 37 mbar	HU	
II2L3P	25, 37 mbar	NL	

<b>Type</b> <i>Typ</i>	<b>Technical Data</b> <i>Technische Daten</i>	<b>Remarks</b> <i>Bemerkungen</i>
BOILER CONDENS+ 24; PULSAR CONDENS 24 PULSAR CONDENS 1.24	nominal heat output: 3,4...20,0 kW nominal heat input (Hi): 3,5...20,6 kW	drinking water: ...24,7 kW
BOILER CONDENS+ 33	nominal heat output: 3,4...24,0 kW nominal heat input (Hi): 3,5...24,7 kW	
PULSAR CONDENS 28	nominal heat output: 4,7...28,0 kW nominal heat input (Hi): 4,8...28,9 (drinking water: ...34,0) kW	drinking water: ...28,9 kW
PULSAR CONDENS 1.32	nominal heat output: 3,8...24,0 kW nominal heat input (Hi): 3,9...24,7 kW	
	nominal heat output: 4,6...32,0 kW nominal heat input (Hi): 4,7...33,0 kW	

#### Hints of Utilization /Remarks

##### *Verwendungshinweise / Bemerkungen*

flue types B23, C13, C33, C43, C53, C63, C83, C93, C13x, C33x, C43x, C53x, C63x, C83x, C93x: according to "installation manual BOILER CONDENS, PULSAR CONDENS..."

Additionally tested appliance categories, supply pressures and countries of destination:

CY: II2H3P (20, 30 mbar)

AL, BG, MK: II2H3P (20, 37 mbar)

In the non-EU countries the conformity approval will be accepted if the Gas Appliance Regulation EU/2016/426 is transferred into national law by this countries.

